

Substation Permit and Licence 25875-D03-2020

Appendix 2 to Decision 25875-D01-2020

October 21, 2020

Fengate Central Utilities Block GP Inc.
Alter Heartland Petrochemical Complex
Central Utility Block Substation

Proceeding 25875
Application 25875-A002

Fengate Central Utilities Block GP Inc., pursuant to Permit and Licence 23975-D04-2018,¹ is the operator of the Heartland Petrochemical Complex Central Utility Block Substation. By Application 25875-A002, registered on September 15, 2020, Fengate applied to the Alberta Utilities Commission for approval to alter and operate the substation and to extend the completion date of the substation to October 31, 2021.

The Commission, pursuant to sections 14, 15 and 19 of the *Hydro and Electric Energy Act*, approved the application in Decision 25875-D01-2020,² and granted Fengate a permit to alter and a licence to operate the substation subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. The substation shall be wholly located in the southeast quarter of Section 25, Township 55, Range 22, west of the Fourth Meridian.
2. Specifications of the substation shall be:
 - (a) two 240/13.8-kilovolt (kV) 51/68/85-megavolt ampere transformers
 - (b) two 240-kV circuits to connect the Heartland Petrochemical Complex Central Utility Block Substation (CUB 672S) to AltaLink Management Ltd.'s Ursus 430S Substation
3. Fengate shall file with the Commission, within 30 days of completing the substation alteration, the energization certificate(s) for the substation issued by Fengate to confirm that the substation has been completed and the substation is being operated in accordance with the provisions of this permit and licence.
4. Unless otherwise authorized by the Commission, alteration of the substation shall be completed by April 30, 2022.

¹ Substation Permit and Licence 23975-D04-2018, Proceeding 23975, Application 23975-A001, November 5, 2018.

² Decision 25875-D01-2020: Fengate Central Utilities Block GP Inc.– Heartland Petrochemical Complex Alterations, Proceeding 25875, Applications 25875-A001 and 25875-A002, October 21, 2020.

Permit and Licence 23975-D04-2018 is rescinded.

The Commission may cancel or suspend this permit and licence, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this permit and licence, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

The Commission may, within 30 days of the date of this permit and licence and without notice, correct typographical, spelling and calculation errors and other similar types of errors and post the corrected permit and licence on its website.

Alberta Utilities Commission

(original signed by)

JP Mousseau
Executive Director, Facilities Division
On behalf of the Alberta Utilities Commission