

Calgary office 1400, 600 Third Avenue S.W. Calgary, Alberta T2P 0G5 Edmonton office Tenth Floor, 10055 106 Street Edmonton, Alberta T5J 2Y2

Substation Permit and Licence 26113-D02-2020

	November 27, 2020
AltaLink Management Ltd.	
Red Deer 63S Substation Alteration	Proceeding 26113
Time Extension	Application 26113-A002

AltaLink Management Ltd., pursuant to Permit and Licence 24513-D03-2019,¹ has approval to alter and operate Red Deer 63S Substation in the Red Deer area. The completion date for the alteration to the substation was stipulated to be on or before December 1, 2020.

By Application 26113-A002, registered on November 24, 2020, AltaLink applied to the Alberta Utilities Commission for approval of a time extension to November 30, 2022, to complete the alteration to the substation.

AltaLink has provided information respecting the need, nature and the duration of the requested time extension. Based upon the information provided, AltaLink has demonstrated that the requested time extension is of a minor nature.

The Commission, pursuant to sections 14, 15 and 19 of the *Hydro and Electric Energy Act*, approves the time extension for the completion of the substation alteration and grants to AltaLink a permit to alter and a licence to operate the substation subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

- 1. The substation shall be wholly located in the southeast of Section 1, Township 38, Range 28, west of the Fourth Meridian.
- 2. Specifications of the substation shall be:
 - (a) two 245/144-kilovolt (kV), 120/160/200-megavolt ampere (MVA) auto transformers
 - (b) one 138/25-kV, 25/33/42-MVA load tap changer transformer
 - (c) one 138/25-kV, 15/20/25-MVA transformer
 - (d) eleven 240-kV circuit breakers
 - (e) eight 138-kV circuit breakers
 - (f) five 25-kV circuit breakers
 - (g) it shall be enclosed within a secure fence and include other substation equipment as described in previous approvals pertaining to the substation

Substation Permit and Licence 24513-D03-2019, Proceeding 24513, Application 24513-A002, May 2, 2019.

- 3. AltaLink shall file with the Commission, within 30 days of completing the substation alteration, the energization certificate(s) for the substation issued by the Alberta Electric System Operator and/or by AltaLink to confirm that the substation alteration has been completed and the substation is being operated in accordance with the provisions of this permit and licence.
- 4. Unless otherwise authorized by the Commission, alteration of the substation shall be completed by November 30, 2022.

Permit and Licence 24513-D03-2019 is rescinded.

The Commission may cancel or suspend this permit and licence, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this permit and licence, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

The Commission may, within 30 days of the date of this permit and licence and without notice, correct typographical, spelling and calculation errors and other similar types of errors and post the corrected permit and licence on its website.

Alberta Utilities Commission

(original signed by)

JP Mousseau Executive Director, Facilities Division On behalf of the Alberta Utilities Commission