

## Connection Order 26188-D03-2021

Appendix 2 to Decision 26188-D01-2021	March 4, 2021
Corse Energy Corp. Connect Huxley 4.95-Megawatt Natural Gas Power Plant to ATCO Electric Ltd.'s 25-kilovolt Distribution System	Proceeding 26188 Application 26188-A001

Corse Energy Corp., by Application 26188-A001, registered on January 21, 2021, applied to the Alberta Utilities Commission for an order to connect its Huxley 4.95-megawatt (MW) natural gas power plant to ATCO Electric Ltd.'s 25-kilovolt distribution system.

The Commission approved the application in Decision 26188-D01-2021,<sup>1</sup> and granted Corse an order to connect its Huxley 4.95-MW natural gas power plant to ATCO Electric Ltd.'s 25-kilovolt distribution system, pursuant to Section 18 of the *Hydro and Electric Energy Act*. This approval is subject to the provisions of the *Hydro and Electric Energy Act* and the *Alberta Utilities Commission Act*, any regulations made under the acts, any orders made under the acts, the Commission rules made pursuant to the *Alberta Utilities Commission Act*, and the following terms and conditions:

1. Corse may connect the power plant to the distribution system in Legal Subdivision 1, Section 30, Township 34, Range 23, west of the Fourth Meridian, as indicated in the application.
2. The specifications of the connection shall be as set out in the application.
3. The connection shall be operated so that except under short-term emergency conditions:
  - (a) The flows of real and reactive power are those for which the connection is designed and which it is intended to carry on a continuous basis.
  - (b) No excessive surges of 60-hertz power or excessive exchange of power frequency harmonics shall occur between the systems connected.
4. This order is not transferable unless approved by the Commission.

<sup>1</sup> Decision 26188-D01-2021: Corse Energy Corp. – Huxley 4.95-Megawatt Natural Gas Power Plant, Proceeding 26188, Application 26188-A001, March 4, 2021.

The Commission may cancel or suspend this order, in whole or in part, in accordance with Section 41 of the *Hydro and Electric Energy Act* or may review this order, in whole or in part, upon its own motion or upon an application by an interested party, in accordance with Section 10 of the *Alberta Utilities Commission Act*.

The Commission may, within 30 days of the date of this order and without notice, correct typographical, spelling and calculation errors and other similar types of errors and post the corrected order on its website.

**Alberta Utilities Commission**

*(original signed by)*

JP Mousseau  
Executive Director, Facilities Division  
On behalf of the Alberta Utilities Commission